Disabled Toilet Kit 1

SKU - APRC0020

The Access Protocol Disabled Toilet Kit has been designed as a standalone system for Sites that require a cost effective, AS3811 standard compliant, audible and visual queue for designated locations in their Facility.

Common uses include Disabled/Universal Access toilets, X-Ray In Use, Assistance Required, Meeting Room Occupied etc.

The system is easy to install, configure and requires minimal maintenance.

In The Kit

Over Door Indicator Light & Buzzer

- Screen Printed Cover with "Disabled Toilet Assistance Required". Custom Text also available.
- 4 x Dual colour (Amber & Red) LED Lights ensure a bright visual indication of an active alarm, dip-switch selectable as flashing or non-flashing.
- Integral Buzzer for audible alarm with selectable steady or pulsing tone (~60dB at 1m)
- Ceiling or Wall Mountable
- System supports up to 4 Over Door Lights

Emergency Call Point

- IP65 Rated for use in wet areas
- Fits in a standard Clipsal 2000 wall box
- Wide range of clear, concise coloured buttons available
- Reassurance lamp
- Large, easy press push button manufactured with ant-bacterium additive as an infection control measure
- Also available with pendant socket & 2m pendant
- System supports up to 4 Call Points

ACCESS PROTOCOL
Advanced Nurse Call Technology

45 Sarich Crt, Osborne Park
www.accessprotocol.com.au
Ph: (08) 9244 5347

Interface Module

* 2 x Internal Relays
  * Mains Failure Relay
  * Alarm Active Relay
* 1.3A Battery Backup
  * ~70hrs Active
  * ~ 700hrs on standby
* Dip switches to select Over Door Light Flashing/Non-Flashing and Sounder to be Steady or Pulsing

Also in the box

* 240v Plug Pack / Transformer to power the Kit & connected devices
* Wiring Diagram - Conveniently located under the Interface Module Lid

Part Numbers	
Disabled Toilet Kit - Complete	APRC0020
Over Door Indicator Light & Buzzer	APRC0021-DT
Emergency Call Point	APRC0024
Interface Module	APRC0023
Power Supply	APRC0022

Technical Specifications	
Power Supply	16v AC 1.38A
Standby Current	10mA
Max Current	100mA
Outputs	1 x Mains Fail Relay (NO & NC) 1 x Active Alarm Relay (NO & NC)
Termination	Terminal Block
Battery Backup	Standby - ~700hrs Active ~70hrs
IP Rating	Call Point - IP65 Housing - IP65

National Nurse Call Contractors Association®

Access Protocol
Advanced Nurse Call Technology

45 Sarich Crt, Osborne Park
www.accessprotocol.com.au
Ph: (08) 9244 5347